

原水測定記録

平成22年9月

【参考値】

月	日	曜日	東コルゲート				西コルゲート				旧東排水管				西U型側溝まわり				調整池			降水量 (mm)
			流入量		電気伝導率	水温	流入量		電気伝導率	水温	流入量		電気伝導率	水温	流入量		電気伝導率	水温		電気伝導率	水温	
			(l/min)	(PH)	(ms/m)	(°C)	(l/min)	(PH)	(ms/m)	(°C)	(l/min)	(PH)	(ms/m)	(°C)	(l/min)	(PH)	(ms/m)	(°C)	(PH)	(ms/m)	(°C)	
9	1	水	58.0	4.8	69	17.5	9.0	6.1	81	18.6		6.0	45	23.5	0.8	5.8	65	25.6	6.4	78	23.8	0
	2	木	55.4	5.0	68	17.5	7.4	6.1	84	19.1		6.1	45	23.2	0.6	5.8	67	24.9	6.4	77	24.3	0
	3	金	55.4	5.0	67	17.4	6.6	6.1	83	18.4		6.1	46	21.8	0.5	5.8	69	23.7	6.5	70	23.9	0
	4	土	55.4	5.0	66	17.4	6.6	6.1	83	18.5		6.1	46	21.4	0.1	5.8	71	23.0	6.4	76	23.8	0
	5	日	50.5	5.0	65	17.4	5.9	6.1	82	18.9		6.1	47	22.4	9.9	6.1	80	18.8	6.5	75	23.9	0
	6	月	50.5	5.0	59	17.5	6.6	6.2	82	18.8		6.2	47	22.5	15.1	6.1	77	19.0	6.4	73	22.4	0
	7	火	55.4	5.1	63	17.4	7.4	6.2	81	18.8		6.4	47	21.5	11.8	6.1	76	19.0	6.4	70	24.1	0
	8	水	63.4	5.1	62	17.6	6.6	6.2	80	18.7		6.6	49	22.5	20.2	6.0	67	19.4	6.5	68	24.7	48.5
	9	木	58.0	5.2	56	17.3	9.9	6.1	80	18.1		6.6	49	20.7	16.3	5.9	72	18.7	6.5	61	21.5	0
	10	金	50.5	5.3	59	17.3	9.0	6.2	80	17.9		6.5	50	20.3	18.8	6.0	75	18.4	6.7	56	22.3	0
	11	土	50.5	5.2	59	17.3	6.6	6.4	78	18.1		7.0	51	19.8	15.1	6.1	73	18.5	6.7	54	21.7	0
	12	日	52.9	5.2	60	17.4	6.6	6.2	77	18.9		6.6	51	21.9	15.1	6.1	72	19.0	6.7	53	23.3	0
	13	月	50.5	5.2	61	17.4	6.6	6.2	77	18.7		6.6	52	22.5	16.3	6.0	67	19.2	6.7	55	24.5	1
	14	火	50.5	5.1	60	17.3	6.6	6.2	76	17.9		6.6	52	18.1	12.8	6.1	70	18.3	6.7	53	22.3	0
	15	水	48.1	5.1	59	17.3	5.3	6.2	76	18.0		6.7	52	19.3	12.8	6.1	69	18.6	6.9	55	22.5	45
	16	木	84.7	5.5	49	17.1	17.5	6.2	73	17.3		6.8	53	18.9	21.6	6.0	61	18.4	6.9	40	21.5	41
	17	金	84.7	5.4	56	17.3	24.6	6.0	77	16.9		6.8	53	17.9	4.1	5.9	58	17.6	6.8	23	20.4	0
	18	土	69.1	5.1	65	17.3	11.8	6.0	80	17.4		6.7	53	17.7	0.0	6.3	69	17.4	6.6	32	19.7	0
	19	日	66.3	5.0	67	17.4	9.9	6.1	80	17.4		6.7	53	19.7	0.0	6.1	71	19.4	6.6	33	19.4	0
	20	月	66.3	4.9	71	17.3	9.9	6.2	80	17.6		6.7	53	18.7	3.1	6.2	75	18.5	6.7	44	20.4	0
	21	火	63.4	4.9	71	17.4	8.1	6.1	80	18.0		6.9	54	19.7	3.1	6.1	79	18.7	6.8	46	20.8	0
	22	水	55.4	4.9	71	17.4	8.1	6.1	79	17.9		6.7	54	19.7	11.8	6.1	81	17.5	6.5	45	20.9	18.5
	23	木	182.4	4.9	48	17.7	43.5	6.2	49	18.0		6.6	54	19.8	78.2	6.0	57	18.4	6.8	21	21.9	34.5
	24	金	121.7	4.9	70	17.0	66.3	6.3	76	16.6		6.8	54	15.0	60.7	5.8	70	16.9	6.7	26	20.1	0
	25	土	102.2	4.8	80	17.0	29.6	6.4	80	16.7		6.7	54	15.6	60.7	5.9	77	17.3	6.7	26	19.6	0
	26	日	102.2	4.7	99	17.1	21.6	6.4	81	16.3		6.7	54	12.8	55.4	6.1	90	16.8	6.7	26	18.0	5.5
	27	月	88.0	4.7	92	17.3	18.8	6.3	83	16.9		6.9	54	15.9	39.2	6.1	95	17.3	6.7	34	16.7	(27)
	28	火	193.1	5.0	62	17.3	66.3	6.0	64	16.8		6.7	54	17.0	63.4	6.0	64	17.7	6.8	26	18.9	(37)
	29	水	143.3	4.8	81	17.1	55.4	6.5	77	16.5		6.6	54	14.2	58.0	5.9	76	17.0	6.6	23	17.9	0
	30	木	121.7	4.6	94	17.2	26.2	5.8	82	16.6		6.6	55	16.5	48.1	5.8	89	17.2	6.5	29	18.2	0

※測定時間は毎日午前9時

※現地計測による計測結果のため参考値

※旧東排水管の流入量については、新プラント受水槽への切替作業のため計測できなかった。(10月1日切替終了)

※9月27、28日の降水量は機械故障により計測できなかったためアメダス(多治見観測所)の値を代用