

原水測定記録【速報】

平成26年4月

月	日	曜日	東コルゲート				西コルゲート				旧排水路				法尻西				調整池放流			降水量 (mm)
			流入量 (l/min)	(pH)	電気伝導率 (mS/m)	水温 (°C)	流入量 (l/min)	(pH)	電気伝導率 (mS/m)	水温 (°C)	流入量 (l/min)	(pH)	電気伝導率 (mS/m)	水温 (°C)	流入量 (l/min)	(pH)	電気伝導率 (mS/m)	水温 (°C)	(pH)	電気伝導率 (mS/m)	水温 (°C)	
4	1	火	160.0	4.5	-	-	40.0	7.1	-	-	1.7	6.3	-	-	83.3	5.8	-	-	-	-	-	0
	2	水	141.7	4.5	-	-	26.7	7.1	-	-	0.0	6.2	-	-	63.3	5.8	-	-	-	-	-	0
	3	木	128.3	4.5	-	-	21.7	7.2	-	-	0.0	6.2	-	-	53.3	5.8	-	-	-	-	-	6.0
	4	金	131.7	4.6	-	-	25.0	6.9	-	-	0.0	6.2	-	-	50.0	5.7	-	-	-	-	-	14.0
	5	土	116.7	4.6	-	-	21.7	7.3	-	-	0.0	6.2	-	-	45.0	5.9	-	-	-	-	-	1.5
	6	日	111.7	4.6	-	-	20.0	7.2	-	-	0.0	6.2	-	-	41.7	5.9	-	-	-	-	-	3.0
	7	月	106.7	4.5	-	-	15.0	6.8	-	-	0.0	6.2	-	-	38.3	5.9	-	-	-	-	-	0
	8	火	101.7	4.6	-	-	18.3	7.3	-	-	0.0	6.2	-	-	36.7	5.9	-	-	-	-	-	0
	9	水	96.7	4.7	-	-	18.3	7.3	-	-	0.0	6.4	-	-	35.0	5.9	-	-	-	-	-	0
	10	木	93.3	4.7	-	-	13.3	7.2	-	-	0.0	6.3	-	-	33.3	5.9	-	-	-	-	-	0
	11	金	88.3	4.7	-	-	11.7	6.7	-	-	0.0	6.3	-	-	33.3	5.9	-	-	-	-	-	0
	12	土	85.0	4.7	-	-	10.0	6.7	-	-	0.0	6.3	-	-	30.0	5.9	-	-	-	-	-	0
	13	日	83.3	4.8	-	-	10.0	6.8	-	-	0.0	6.3	-	-	30.0	6.0	-	-	-	-	-	0
	14	月	80.0	4.5	-	-	10.0	6.8	-	-	0.0	6.3	-	-	28.3	6.0	-	-	-	-	-	0
	15	火	76.7	4.7	-	-	8.3	6.7	-	-	0.0	6.3	-	-	26.7	6.0	-	-	-	-	-	0
	16	水	75.0	4.8	-	-	8.3	6.7	-	-	0.0	6.3	-	-	26.7	6.0	-	-	-	-	-	0
	17	木	73.3	4.6	-	-	8.3	6.8	-	-	0.0	6.3	-	-	25.0	6.0	-	-	-	-	-	0
	18	金	73.3	4.8	-	-	6.7	6.7	-	-	0.0	6.3	-	-	25.0	5.9	-	-	-	-	-	2.5
	19	土	70.0	4.7	-	-	6.7	6.7	-	-	0.0	6.3	-	-	25.0	6.0	-	-	-	-	-	0
	20	日	70.0	4.8	-	-	6.7	6.7	-	-	0.0	6.3	-	-	25.0	6.1	-	-	-	-	-	5.0
	21	月	71.7	4.7	-	-	8.3	6.6	-	-	0.0	6.3	-	-	23.3	6.1	-	-	-	-	-	7.5
	22	火	70.0	4.6	-	-	6.7	6.7	-	-	0.0	6.3	-	-	23.3	6.0	-	-	-	-	-	0
	23	水	68.3	4.6	-	-	6.7	6.6	-	-	0.0	6.3	-	-	23.3	6.1	-	-	-	-	-	0
	24	木	66.7	5.2	-	-	5.0	6.7	-	-	0.0	6.3	-	-	21.7	6.1	-	-	-	-	-	0
	25	金	65.0	5.3	-	-	5.0	6.6	-	-	0.0	6.3	-	-	21.7	6.1	-	-	-	-	-	0
	26	土	65.0	5.3	-	-	5.0	6.7	-	-	0.0	6.3	-	-	20.0	6.1	-	-	-	-	-	0
	27	日	65.0	5.3	-	-	5.0	6.7	-	-	0.0	6.3	-	-	20.0	6.1	-	-	-	-	-	0
	28	月	65.0	5.3	-	-	5.0	6.7	-	-	0.0	6.3	-	-	21.7	6.1	-	-	-	-	-	1.0
	29	火	66.7	5.3	-	-	6.7	6.9	-	-	0.0	6.3	-	-	20.0	6.1	-	-	-	-	-	16.5
	30	水	93.3	5.6	-	-	18.3	7.4	-	-	1.7	6.3	-	-	26.7	5.9	-	-	-	-	-	34.0

※pHはプラントデータの午前9時の測定値を転記している。
 ※流入量はプラントデータの日平均値を転記している。